

Newbern Downtown Enhancement Phase II
City of Newbern, Dyer County, Tennessee
Pin No. 126670.00
TLM Job No.: J-6034



ADDENDUM NO.: 2

February 21, 2022

This Addendum shall apply to the Drawings and Specifications for the above-referenced project and shall be bound into and made a part of the Construction Documents issued by TLM Associates, Inc., titled as indicated above.

Item No. 1: Reference detail 6/2A Modified Trench Drain. The steel bar grate will be 1/2" or 3/4" thickness x 8" with 3/8" openings. Bar grate shall be sized to support heavy pedestrian loading. Submit product data and/or shop drawings of bar grate to Engineer and Landscape Architect for approval.

Please acknowledge receipt of this Addendum in the appropriate location on the Bid Form.

Sincerely,

Ritchie Smith

